

WELL REPORTS DATED 12/02/10											
Sr. No.	Ward	Beat No.	Location of Wells	Water Test Report.	Status of Work.	Whether the water is salty(By Physical Inspection)	Yield in Litrs/Hour	Whether the Water tank & Pump Installation is feasible.	Whether the water filtration plant is feasible.	Estimated cost in Rs.	Remarks.
1	K/EAST	66	Dattaguru Krida Mandal		Completed	Yes	3185 Lit/Hr	Yes	No	454500	
2	K/EAST	66	Mayamuttu Chawl		Completed	Yes	190 lit/hr	No	No		
3	K/EAST	66	Kathiyawadi Chawl		Completed	Yes	5808 ltr/hr	Yes	No		
4	K/EAST	66	Natwar Nagar Road No.4		Completed	Yes	9500 ltr/hr	No	No		
5	K/EAST	66	Rane Wadi		Completed	Yes	2837 lit/hr	No	No	498000	
6	K/EAST	66	Mery Chawl		Completed	Yes	990 lit/hr	Yes	No		
7	K/EAST	66	Shamimmulla Chawl		Completed	Yes	6362 lit/hr	Yes	No		
8	K/EAST	66	Sai Dham		Completed	Yes	3167 lit/hr	Yes	No		
9	K/EAST	67	Dudhnathbhaya Chawl, Gandhi Nagar.		Completed	Yes	130 lit/hr	No	No	208500	
10	K/EAST	67	Satyanarayan Chawl		Completed	Yes	712lit/hr	No	No		
11	K/EAST	67	Bhagatsingh Chawl		Completed	Yes	410lit/hr	No	No		
12	K/EAST	67	Kamala Kutir Chawl, Shiv Tekdi		Completed	Yes	1530 lit/hr	No	No		
13	K/EAST	67	Shekhrajsingh Chawl, Ramwadi		Completed	Yes	2869 lit/hr	No	No		
14	K/EAST	67	Patil Chawl, Gandhi Nagar.		Completed	Yes	340 lit/hr	No	No		
15	K/EAST	67	Madan Shankar Chawl, Mahara j Bhavan.		Completed	Yes	360 lit/hr	No	No		
16	K/EAST	67	Kailash Chawl, Shiv Tekdi		Completed	Yes	1980 lit/hr	Yes	No		
17	K/EAST	68	Sai Temple, Sham Nagar		Completed	Yes	3100 ltrs/hr	No	No		

18	K/EAST	68	Adarsh Nagar		Completed	Yes	2900 ltr/hr	Yes	No	151500	
19	K/EAST	68	Durga Nagar		Completed	Yes	1200 ltr/hr	No	No		
20	K/EAST	69	Chandrodaya chawl		Completed	Yes	6050 ltr/hr	YES	NO	120300	
21	K/EAST	69	Ramanath Yadav Chawl		Completed	Yes	3800 ltr/hr	NO	NO		
22	K/EAST	69	Santoshi Mata Chawl		Completed	Yes	800 ltr/hr	NO	NO		
23	K/EAST	71	Lajja Compound, A. N. Tiwari Marg		Completed	Yes	2800 ltr/hr	NO	No	499600	
24	K/EAST	71	Janseva Chawl, Nochulus Wadi Road		Completed	Yes	3200 ltr/hr	Yes	No		
25	K/EAST	71	Behind Bhuta Compound		Completed	Yes	-	NO	No	474900	
26	K/EAST	71	Plot No.182, near Koyla Compound, Gajlaxmi Bldg.		Completed	Yes	550 lit/hr	NO	No		
27	K/EAST	71	Maganbai Dodia, R. K.Singh Road		Completed	Yes	3500 ltr/hr	Yes	No		
28	K/EAST	71	Vazir Glass Compound, A.K Road		Not started due to Court Matter	Yes	-	NO	No	474300	
29	K/EAST	71	Shambhuwadi, Opp. Pump House Subway		Completed	Yes	5500 lit/hr	Yes	No		
30	K/EAST	71	Harbantalal Molakram Chawl , Ambewadi		Completed	Yes	5940 lit/Hr	NO	No		
31	K/EAST	71	Sadhuwala, near Railway Line at Mogra Service Road		Work Done by Mhada	Yes	-	No	No	71700	
32	K/EAST	71	Saibaba Mandir Nr. Reliance Company		Completed	Yes	1250 lit/hr	No	No		
33	K/EAST	71	Sigma Paint, A.N. Tiwari Marg		Completed	Yes	2000 lit/hr	No	No		
34	K/EAST	72	Cinemax Theater Prakashwadi		Completed	Yes	234 lit/hr	NO	NO	170705	
35	K/EAST	72	Near rahiwashi seva Sangh, Malpa Dongri		Completed	Yes	2765 ltr/hr	YES	NO		
36	K/EAST	72	Near Jai Santoshi Mata Mandir, Hanjar Nagar		Completed	Yes	955 ltr/hr	NO	NO		
37	K/EAST	72	Near Shree ganpati Mandir Malpa Dongri		-	-	-	YES	YES		
38	K/EAST	72	In Devrang Chawl , Datta Jagdamba Mandir Marg		-	-	-	YES	NO		
39	K/EAST	73	Charatsingh Colony Compound, Chakala		Yield not taken due to seepage and dirty water	Yes	-	NO	NO		

40	K/EAST	73	SEEPZ, MIDC		Work not done as maintain by seepz & Due to Security reasons	NOT DONE	-	NO	NO	178300	
41	K/EAST	73	Konkan Nagar Soc.		Completed	Yes	2100 lit/hr	NO	NO		
42	K/EAST	73	Ganesh Nagar		Completed	Yes	2700 lit/hr	YES	NO		
43	K/EAST	73	Shreya House,		Water Problem	Yes	-	NO	NO		
44	K/EAST	74	Khan chawl ,Mapkhan nagar		Completed	Yes	1050 lit/hr	YES	NO		
45	K/EAST	74	Allarakha chawl ,Mapkhan nagar		Completed	Yes	450 lit/hr	YES	NO		
46	K/EAST	74	Fire Brigade		Completed	Yes	1500 ltr/hr	NO	NO		
47	K/EAST	74	Mangu Mhatre chawl		Completed	Yes	1575 lit/hr	YES	NO	123000	
48	K/EAST	74	SRA Bldg. Kadam Wadi		Not Taken as side wall Collaps. Required total construction of well	Yes	-	NO	NO		
49	K/EAST	74	Rahul CHS Kadamwadi		Completed	Yes	1520 lit/hr	NO	NO		
50	K/EAST	74	Adarsha nagar		Completed	Yes	2500 ltr/hr	YES	NO		
51	K/EAST	74	Leela Buisiness Park -1		Completed	Yes	3850 lit/hr	OWN SET UP OF PRIVATE COMPANY	NO	208000	
52	K/EAST	74	Leela Buisiness Park -2		Completed	Yes	3700 ltrs/hr				
53	K/EAST	74	Fernandis House, Marol		Completed	Yes	2700 lit/hr		NO		
54	K/EAST	75	Borosil Glass works,		Completed	Yes	1557 ltr/hr		NO		
55	K/EAST	75	Cargo Complex, Sutar Pakhadi		Work Cancel	-		-	NO	259000	
56	K/EAST	75	Sai Temple ,Sutar Pakhadi		Completed	Yes		-	NO		
57	K/EAST	75	A-1 Soc., Salim Compound , Chimat Pada		Completed	Yes	3052 ltr/hr	YES	NO		
58	K/EAST	75	CTS No.16/13 Ruby Coach RG		Completed	Yes	4550 ltr/hr	YES	YES	68700	
59	K/EAST	76	Bamanpuri J.B. Nagar		Completed	Yes	2712 ltr/hr	Yes	No	173400	
60	K/EAST	76	Durgadevi Mandir, Deolwadi		Completed	No	3215 ltr/hr	Yes	No		
61	K/EAST	76	Green house, Pipeline		Completed	Yes	2205 ltr/hr	Yes	No		
62	K/EAST	76	Taxiwala Chawl, Lelewadi		Yield not taken due to seepage		-		No		
63	K/EAST	77	Thakur chawl Bamanwada		Completed	Yes	2450 Lit/Hr.	Yes	No		

64	K/EAST	77	Kurban Chawl, Kajuwadi		Completed	Yes	2475 ltr/hr	Yes	No	148800	
65	K/EAST	77	Joshi Chawl, Sahar Road, Near Chandrabai chawl		Completed	Yes	3180 ltrs/hr	Yes	No		
66	K/EAST	77	Rajaram wadi, Near Service Road		Completed	Yes	1850 ltr/hr	No	No		
67	K/EAST	77	Kabir Nagar, Near café Sahara Hotel, Sahar Road		Completed	Yes	2512 ltr/hr	Yes	No		
68	K/EAST	78	Urmila Apt.		Completed		2200 ltr/Hr			109200	
69	K/EAST	78	Thomas Chawl		Completed		950ltr/hr				
70	K/EAST	78	Jumbo Darshan				-				
71	K/EAST	78	Daruwala Chawl		Completed		1500ltr/hr.				
72	K/EAST	79	Kirtikar Chawl,Shivaji Nagar.		Completed	Yes	1148 lit/Hr	Yes	No	181950	
73	K/EAST	79	Surajben compound.Sh ahaji Raje Marg.		Completed	Yes	964 ltr/hr	Yes	No		
74	K/EAST	79	Pandurang Chawl, Shivaji Nagar,		Completed	Yes	931 ilr/hr	Yes	No		
75	K/EAST	79	Pawar Chawl, Shahaji Raje Marg		Completed	Yes	1011 ltr/hr	Yes	No		
76	K/EAST	79	Geetanjali, Shahaji Raje Road.		Completed	Yes	2548 ltr/hr	Yes	No		
77	K/EAST	79	Chandrabai Chawl, Shivaji Nagar		Completed	Yes	2945 ltrs/hr	Yes	No	176700	
78	K/EAST	79	Chavan Chawl, Shahaji Raje Marg.		Completed	Yes	962 ltr/hr	Yes	No		
79	K/EAST	79	Kalavati Chawl, Shivaji Nagar.		Completed	Yes	1124 ltr/hr	Yes	No		
80	K/EAST	79	Narayan baug, Shivaji Nagar.		Completed	Yes	1224 ltr/hr	Yes	No		
81	K/EAST	79	Juhukar Wadi, Sambhaji Nagar		Completed	Yes	806 lit/hr	Yes	No		
82	K/EAST	80	Vanmali Compound		Completed	Yes	1794 ltr/hr	Yes	No	302400	
83	K/EAST	80	F.P. No- 424(P.G.)		Completed	Yes	1271 ltr/hr	Yes	No		
84	K/EAST	80	Gabheri chawl.,Dayald as road		Completed	Yes	3270 ltr/ hr	Yes	No		
85	K/EAST	80	Amrut Wadi		Completed	Yes	1550 ltrs/hr	Yes	No		