

Status of Wells

Sr.No	Ward	Beat No	Locations of Wells	Water Test Report	Status of work	Wheather the water is Salty (By physical Inspection)	Yield in Litres/Hour	Wheather the water tank & Pump installation is feasible	Wheather the water filtration plant is feasible	Estimated cost in Rs.	Remarks
1	M/East	134	Mahatma Phule Nagar	Report to be received	Completed	Salty	Below 2000	No	No	Rs. 700,000.00	
2	M/East	134	Bharat Nagar	Report to be received	Completed	Salty	Below 2000	No	No		
3	M/East	134	NAD Colony	Report to be received	Completed	Salty	Below 2000	No	No		
4	M/East	135	Jamliya House, V.N.Purav Marg.	chemically Fit for Potable use	Completed	No smell, clear water with few brown & white particles	6000	Yes	Yes	Rs. 667,000	
5	M/East	135	Near Muthumariamman Temple, Cheetah camp, Mirza Galib Road	Unfit for potable purposes	Completed	Sewage smell, turbid water with many brown & white particle	900	No	No	Rs. 987,000.00	
6	M/East	135	N' Line, behind Metro Hotel D sector, Cheetah camp.	Unfit for potable purposes	Completed	No smell, clear water with few brown & white particles	4015	Yes	No		
7	M/East	135	C' sector, I- line beside Shilpa Comm. Cheetah camp	chemically Fit for Potable use	Completed	No smell, clear water with few brown & white particles	762	No	No	Rs. 925,500	
8	M/East	135	B' sector, Cheetha camp	-	Completed	No smell, clear water with few brown & white particles	330	Yes	No		

9	M/East	135	E' sector, Cheetah camp behind Police Chowky	Unfit for potable purposes	Completed	Sewage smell, turbid water with many brown & white particle	900	Yes	No	Rs. 75,000.00	
10	M/East	135	D' sector O line, beside ideal School, Cheetah camp,	Unfit for portable purposes	Completed	Sewage smell, turbid water with many brown & white particle	845	No	No	Rs. 922,100.00	
11	M/East	135	D, sector, I-1 line Cheetha Camp.	Unfit for portable purposes	Completed	Sewage smell, turbid water with many brown & white particle	460	No	No		
12	M/East	135	D, sector, F line Cheetha Camp.	chemically Fit for Potable use	Completed	No smell, clear water with few brown & white particles	5496	Yes	No		

13	M/East	136	Trombay Ekvira	chemically Fit for Potable use	Completed	No smell, clear water with few brown & white particles	1782	Yes	No	Rs. 999,700.00	
14	M/East	136	Trombay Gurukripa	chemically Fit for Potable use	Completed	No smell, clear water with few brown & white particles	3440	Yes	No		
15	M/East	136	Trombay, Samudra Manthan	chemically Fit for Potable use	Completed	No smell, clear water with few brown & white particles	4650	No	No		
16	M/East	136	Trombay, Fish Market	Unfit for potable purposes	Completed	Sewage smell, turbid water with many brown & white particle	1206	No	No		
17	M/East	136	Shivmandir, Borba devi	Unfit for potable purposes	Completed	Sewage smell, turbid water with many brown & white particle	406	No	No		
18	M/East	136	Crescent School Paylipada	Unfit for potable purposes	Completed	No smell, clear water with few brown & white particles	1075	No	No		
19	M/East	136	Cemetery, Mandala	Unfit for potable purposes	Completed	No smell, clear water with few brown & white particles	2386	Yes	No		

20	M/East	138	Near roshan Garment, Tatanagar Road Govandi	Unfit	Completed	No smell, Clear water with few brown & white particles	1171.12	Not Feasible	No	Rs. 790,000.00	
21	M/East	138	Near Laxmi General Stores, Tatanagar Road Govandi	Unfit	Completed	No smell, Clear water with few brown & white particles	994.88	Not Feasible	No		
22	M/East	138	Near Maharashtra Dresses, Tatanagar Road Govandi	Unfit	Completed	No smell, Clear water with few brown & white particles	1282.13	Not Feasible	No		
23	M/East	138	Near Qureshi Masjid, Tatanagar Road Govandi	Unfit	Completed	No smell, Clear water with few brown & white particles	1375.57	Not Feasible	No		
24	M/East	138	Near Vikas Beer Bar, Tatanagar Road Govandi	Unfit	Completed	No smell, Clear water with few brown & white particles	1343.65	Not Feasible	No	Rs. 275,000.00	
25	M/East	138	Near Samrat Bakery, Tatanagar Road Govandi	Unfit	Completed	No smell, Clear water with few brown & white particles	1051.55	Not Feasible	No		
26	M/East	139	Borla Govandi	Chemically Fit for Potable use	Completed	No smell, Clear water with few brown & white particles	8577	Yes	No	Rs.873,179.43	
27	M/East	139	Chinchpada	Chemically Fit for Potable use	Completed	No smell, Clear water with few brown & white particles.	11539	Yes	No		

28	M/East	139	M.D.C Home, Near Zarina Park	Chemically Fit for Potable use	Completed	No smell, Clear water with few brown & white particles	16164	Yes	No	Rs.747,398.11	
29	M/East	139	Children Home, Near Bajaj Kutir Work Shop	Chemically Fit for Potable use	Completed	No smell, Clear water with few brown & white particles	14949	No	No	Rs.446526.86	
30	M/East	139	Children Home, Near Vaity Chawl.	Chemically Fit for Potable use	Completed	No smell, Clear water with few brown & white particles	8059	No	No	Rs. 565,001.74	
31	M/East	139	Children Home, Near Jamnalal Bajaj House	Report to be received	Completed			No	No		
32	M/East	139	Shivneri Zopadpatti,	Chemically Fit for Potable use	Completed	No smell, Clear water with few brown & white particles	4328	No	No	Rs. 554,090.65	
33	M/East	139	Near Glass Company	unfit for potable use	Completed	Sewage smell, turbid water with many brown & white particle	7914.37	No	No		

34	M/East	139	Deonar village	Chemically Fit for Potable use	Completed	No smell, Clear water with few brown & white particles	4768	Yes	No	Rs.702,724.03	
35	M/East	139	Siddheshwar Wadi	Unfit for potable use	Completed	No smell, Clear water with few brown & white particles	1780	No	No		
36	M/East	139	Deonarpada, Near Pawar communication	Unfit for potable use	Completed	Sewage smell, turbid water with many brown & white particle	7934	No	No		
37	M/East	139	Children Home, Near library	Chemically Fit for Potable use	Completed	No smell, Clear water with few brown & white particles	11871	No	No	Rs.455,971.04	
38	M/East	139	Nayan House Dattaguru	unfit for potable use	Completed	No smell, Clear water with few brown & white particles	19899	No	No	Rs.869,176.17	
39	M/East	139	C- 3 Bungalow Dattaguru	Chemically Fit for Potable use	Completed	No smell, Clear water with few brown & white particles	16052	No	No	Rs.872,088.12	

40	M/East	139	Tata Nagar	Unfit for potable use	Completed	No smell, Clear water with few brown & white particles	2550	No	No	Rs.602,543.60	
41	M/East	139	Tata Nagar, Bhim Seva Sangh	Unfit for potable use	Completed	No smell, Clear water with few brown & white particles	3419	No	No		
42	M/East	139	Jaggannath Patilwadi	Unfit for potable use	Completed	No smell, Clear water with few brown & white particles	4534	Yes	No	Rs.488,186.06	
43	M/East	139	Govandi, Gaondevi Mandir	Chemically Fit for Potable use	Completed	No smell, Clear water with few brown & white particles	4329	No	No		
44	M/East	139	Sharad wadi, Near Ashok Kharat house	Chemically Fit for Potable use	Completed	No smell, Clear water with few brown & white particles	9043	Yes	No	Rs.446,881.63	
45	M/East	140	Sharad wadi, Near Sauchalya	Chemically Fit for Potable use	Completed	No smell, Clear water with few brown & white particles	1256	Yes	No		

46	M/East	140	Prabhudha Nagar, Near Vidhate House	Report to be received	Completed	No smell, Clear water with few brown & white particles	2649	No	No	Rs.597,027.13	
47	M/East	140	Prabhudha Nagar, Near Bhimtola gate	Report to be received	Completed	No smell, Clear water with few brown & white particles	6769	No	No		
48	M/East	140	Prabhudha Nagar. Near Bhanudas Jadhav House	Report to be received	Completed	No smell, Clear water with few brown & white particles	4526	No	No		
49	M/East	140	J.J.Wadi	unfit for potable use	Completed	Seware smell, turbid water with many brown & white particle	19596	No	No	Rs.455,500.48	
50	M/East	140	Shivaji Nagar	Chemically Fit for Potable use	Completed	No smell, Clear water with few brown & white particles	4178	No	No	Rs.697,283.62	
51	M/East	140	Aziz Baug	unfit for potable use	Completed	No smell, Clear water with few brown & white particles	5024	No	No		

52	M/East	140	Julien Wadi	Chemically Fit for Potable use	Completed	No smell, Clear water with few brown & white particles	7212	No	No	Rs.638,801.27	
53	M/East	140	Ganesh Wadi	Chemically Fit for Potable use	Completed	No smell, Clear water with few brown & white particles	5841	No	No		
54	M/East	140	Wadavali Village	unfit for potable use	Completed	No smell, Clear water with few brown & white particles	1538	No	No	Rs.379,791.37	
55	M/East	140	Indira Nagar	unfit for potable use	Completed	No smell, Clear water with few brown & white particles	2550	No	No		
56	M/East	140	Sharadwadi, Near Tukaram Chavan House	Chemically Fit for Potable use	Completed	No smell, Clear water with few brown & white particles	7474	No	No		
57	M/East	140	Prabhudha Nagar, Near Sunil Kiran House	Chemically Fit for Potable use	Completed	No smell, Clear water with few brown & white particles	11693	No	No	Rs.547,493.17	

58	M/East	140	Panjarapol Kamawadi	Unfit for potable use	Completed	No smell, Clear water with few brown & white particles	7259	No	No	Rs.871,963.17	
59	M/East	140	Ashok Nagar	Unfit for potable use	Completed	No smell, Clear water with few brown & white particles	3768	Yes	No		
60	M/East	140	Shivaji Nagar	Unfit for potable use	Completed	No smell, Clear water with few brown & white particles	6838	No	No		
61	M/East	140	Acharyawadi Plot No.2	Unfit for potable use	Completed	No smell, Clear water with few brown & white particles	7536	Yes	No	Rs.557,841.82	
62	M/East	141	Prayag Nagar	Unfit for potable use	Completed	No smell, Clear water with few brown & white particles		No	No	Rs.596,289.06	
63	M/East	141	Vishnu Nagar	Report to be received	Completed	No smell, Clear water with few brown & white particles	5288	No	No		

64	M/East	141	Bharat Nagar, Near Durga Chawl	Report to be received	Completed	No smell, Clear water with few brown & white particles	8907	Yes	No	Rs.810,040.48	
65	M/East	141	Bharat Nagar, Near Mahalaxmi Mandir	Report to be received	Completed	No smell, Clear water with few brown & white particles	7984	No	No		
66	M/East	141	Bharat Nagar, Near Shivrao tambe house	unfit for potable use	Completed	Sewage smell, turbid water with many brown & white particle	5699	No	No	Rs.602,928.73	
67	M/East	141	Bharat Nagar, Near Ganesh Gully	unfit for potable use	Completed	No smell, Clear water with few brown & white particles	7429	No	No		
68	M/East	141	Prayag Nagar, Near Singh House	Report to be received	Completed	No smell, Clear water with few brown & white particles	8024	No	No	Rs.365,200.81	
69	M/East	139	RNA Park	Report to be received	Completed	No smell, Clear water with few brown & white particles	7359	Yes	No	Rs.397,991.76	
70	M/East	141	Gawanpada Village	Unfit forpotable use	Completed	Sewage smell, turbid water with many brown & white particle	5769	No	No		

71	M/East	141	Priyadarshini Society, Ayodhya Nagar	Report to be received	Completed	No smell, Clear water with few brown & white particles	2671	No	No	Rs.739,657.64	
72	M/East	141	Shastri Nagar	Report to be received	Completed	Sewage smell, turbid water with many brown & white particle	2769	No	No		
73	M/East	141	Bharat Nagar, Near Gausiya Bakery	Report to be received	Completed	No smell, Clear water with few brown & white particles	8742	No	No	Rs.749,090.54	
74	M/East	141	Bharat Nagar, Near Banjara Tanda	Report to be received	Completed	No smell, Clear water with few brown & white particles	9308	Yes	No		
75	M/East	141	Bharat Nagar, Opp Narayan Acharya School	Report to be received	Completed	No smell, Clear water with few brown & white particles	1808	No	No	Rs.791,322.55	
76	M/East	141	Bharat Nagar, Near Vilas Dhondu House	Report to be received	Completed	No smell, Clear water with few brown & white particles	6208	No	No		