

BRIHANMUMBAI MUNICIPAL CORPORATION

Hydraulic Engineer's Department (O. C. Div.)

AMC(P)/10313 Dt – 12.04.2024

Subject: “Replacement of 7.5 MVA damaged Transformer by 10 MVA Transformer with Allied Electrical work at 100 kV Substation, Pise.”

Ref: Bid No. : 2024_MCGM_1033672_1

CORRIGENDUM – I

With reference to above, following Corrigendum is issued:

SBD Clause	Particulars	Existing Condition	Revised Condition
Page No. 126 Scope of work point No.2	Lightning Arrestor	The Contractor shall supply Lightning Arrestors as per IS.	The Contractor shall supply Lightning Arrestors with surge monitor counter of range 0-5mA and 25 sq. mm, 3 mtr, single core multi stranded flexible copper cable with copper lugs on both side for connection as per IS.
General specifications Clause no.17 Page No. 99 Payment Condition	Payment Condition	Payment will be made after successful completion of work within 30 days after receipt of correct bill as per contract terms and condition.	60% payment will be made after delivery of material at site on pro rata basis, within 30 days after submission of invoice and remaining payment will be made after satisfactory completion of work, within 30 days after submission of invoice.

Sd/-

E.E.(M&E)Pise